Chlorine Test Kit

Free and Total Chlorine
DPD 1 & 3

MARINE CARE

Marine Care BV
Oude Maasweg 35
Port # 4005
3197 KJ Rotterdam (Botlek)
T. +31 (0)10 2950342
F. +31 (0)10 2950345
E. supply@marinecare.nl
W. www.marinecare.nl

HEALTH & SAFETY

MARINE CARE

Some reagents required for tests shown in this booklet are classed as hazardous and as such, a minimum protection of gloves (rubber or plastic) and safety goggles/ spectacles or facemask **MUST BE WORN**.

In addition please note and observe the Risk and Safety phrases on each reagent container and follow handling guidelines as instructed.

GENERAL NOTES

⇒ Avoid contact with skin or eyes

⇒ In case of contact with skin or eyes rinse immediately with plenty of running tap water, and seek medical attention

⇒ Seek attention if irritation persists

⇒ In case of ingestion, wash the mouth out thoroughly with water, try to vomit and seek medical attention

MARINE CARE BV
Oude Maasweg 35
Port # 4005
3197 KJ Rotterdam (Botlek)
T. +31 (0)10 2950342
F. +31 (0)10 2950345
E. supply@marinecare.nl
W. www.marinecare.nl

FREE & TOTAL **CHLORINE** (0 - 1 mg/l)

Note:

1. Take care not to shake or aerate the sample
2. Store the reagents in a cool and dry place

mg/l = ppm

Fill one (1) tube with **10 ml** of sample. Place in the left side of the comperator	Add one **DPD N0.1 tablet** to the order tube containing a small amount of the sample	Fill the tube to the **10 ml mark** fit the cap and mix thoroughly Place in right side Of comparator	Rotate the disc until colour match is obtained Record disc reading of **Free Chlorine**	Take the right hand tube from the comparator Add one (1) **DPD N0.3 tablet** fit the cap and mix thoroughly Place in right side Of comparator	Rotate the disc until colour match is obtained Record disc reading of **Total Chlorine**
					

Combined Chlorine in mg/l or ppm = Total Chlorine - Free Chlorine

Chlorine Testkit		
Description	Amount	
Free Chlorine 0 - 1 mg/l		
Reagent DPD1, 100 tablets	1	
Reagent DPD3, 100 tablets	1	
Test tube square10 ml, with lid	2	
Comparator	1	
Chlorine Disc 0 - 1 mg/l	1	

WHEN IN DOUBT

⇒ Contact us for advise
⇒ E-mail us all test figures over a period of at least 3 months

MARINE CARE

MARINE CARE BV
Oude Maasweg 35
Port # 4005
3197 KJ Rotterdam (Botlek)
T. +31 (0)10 2950342
F. +31 (0)10 2950345
E. supply@marinecare.nl
W. www.marinecare.nl